



CLONTZ PARK BOAT RAMP

SMITHFIELD, VIRGINIA

IFB NO. 16-12

Pre-Bid ADDENDUM No. 2

October 4, 2016

Pre-Bid ADDENDUM NO. 2

Bidders are requested to attach this Addendum to the inside front cover of the bid form.

Please inform all concerned that the Documents are modified by this Addendum.

Contractors are required to review each clarification specifically as it pertains to the Contract Documents. Clarifications to the Contract Documents are specifically indicated in the document below. Contractors must acknowledge receipt of this Addendum No. 1 on the Bid Form where required.

Clarifications to the Plans

1. ***Sheets CS501 & SC502:*** The 20-foot by 70-foot concrete boat ramp pavement section shall have continuous reinforcing, consisting of #4 bars at 12 inches, on-center and each way. Reinforcing steel shall be placed in the center of the concrete slab thickness (minimum 3" cover).
2. ***Sheet CL100:*** Contractors are advised that this plan sheet is For Information Purposes Only. The Town of Smithfield will contract directly with Dominion Virginia Power for the design and installation of the lighting poles, fixtures, and conduit system. The Contractor shall coordinate with and make reasonable accommodations to facilitate the installation of the lighting system by Dominion Virginia Power.