

Addendum #1 to RFP for Street Maintenance Services - June 5, 2019

- 1) With regards to this RFP, traffic control will be the responsibility of the contractor and will follow the current VDOT Work Area Protection guidelines;
- 2) With regards to all noted items, it should be understood this work involves removal and replacement;
- 3) With regards to the road overlay, a 2 inch milling of the complete surface shall be performed with disposal of the milled material;